

Number	KIP-15127/E	Replaces	KIP-15070/E
Issued	14-09-2016	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	150101967/3	Page	1 of 2
PIN	0476CQ1967		

EC TYPE EXAMINATION CERTIFICATE

Kiwa Cermet Italia, notified body for council Directive 92/42/EEC, hereby declares that according to article 4 of commission regulation (EU) No. 813/2013 the products

Boiler bodies

Trade mark: **RIELLO**
Models: TAU 115 N, TAU 150 N, TAU 210 N,
TAU 270 N, TAU 350 N
Manufactured by **RIELLO S.p.A.**
Legnago (VR) - Italy


Have achieved the following (see Annex 1) full and part load efficiencies.

The assessment test have been performed using the following standards as guidelines:

EN 303-1:1999
EN 303-1/A1:2003
EN 303-3:1998
EN 303-3/A2:2004
EN 303-3/AC:2006
EN 677:1998

The validity of this certificate can be verified by means of a register available on the website www.kiwa.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia

Chief Operating Officer
Giampiero Belcredi

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl
Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)
Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it
www.kiwacermet.it

GASTEC



SGQ N° 007A SSI N° 006G
SGA N° 010D FSM N° 004I
PRD N° 069B

Number	KIP-15127/E	Replaces	KIP-15070/E
Issued	14-09-2016	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	150101967/3	Page	2 of 2
PIN	0476CQ1967		

EC TYPE EXAMINATION CERTIFICATE

ANNEX 1

Models:

	TAU 115 N	TAU 150 N	TAU 210 N
Full load 80/60°C	97,7 %	97,7 %	97,7 %
Aver. load 80/60°C	97,5 %	97,6 %	97,8 %
Part load at 30°C	108,3 %	108,5 %	109,3 %
C.Heater?	No	No	No
B ₁ Boiler?	No	No	No
Type of boiler:	Condensing	Condensing	Condensing

	TAU 270 N	TAU 350 N
Full load 80/60°C	97,9 %	98,2 %
Aver. load 80/60°C	98,0 %	98,2 %
Part load at 30°C	109,2 %	108,7 %
C.Heater?	No	No
B ₁ Boiler?	No	No
Type of boiler:	Condensing	Condensing

Note:

C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)

B₁ Boiler = B₁ according CEN/TR 1749:2014

Type of boiler = "Condensing Boiler" or "Low Temperature Boiler" or Other Boiler"

Efficiency's values have been measured with gas G20