



DECLARATION

Issued	22-12-2021	Scope	---
Report	2005430	Page	1 of 1
PIN	0476DM5430		

Herewith Kiwa Cermet Italia S.p.a., based on tests supplied by the manufacturer, declares that the central heating condensing boilers

Test report no.	2005430
Trade mark:	RIELLO
Models:	CONDEXA HPR 35 CONDEXA HPR 45

are fitted for outdoor use in partially protected place according to EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016 with minimum ambient temperature of $> 0^{\circ}\text{C}$.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadrano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it
www.kiwacermet.it

Industry Division Manager
Maurizio Lorenzon

GASTEC