



Number	KIP-15217/E	Replaces	KIP-15140/E
Issued	23-12-2016	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	150200348/2	Page	1 of 2
PIN	0476CQ0348		

EC TYPE EXAMINATION CERTIFICATE

Kiwa Cermet Italia, notified body for council Directive 92/42/EEC, hereby declares that according to article 4 of commission regulation (EU) No. 813/2013 the product

Central heating condensing boiler

Trade mark: **RIELLO**

Models: TAU 115 N OIL, TAU 150 N OIL, TAU 210 N OIL,
TAU 270 N OIL, TAU 350 N OIL,

Manufactured by **RIELLO S.p.A.**
Legnago (VR), Italy

Have achieved the following (see Annex 1) full and part load efficiencies.

The assessment test have been performed using the following standards as guidelines:

EN 15034:2006
EN 15034/AC:2008
EN 303-1:1999
EN 303-1/A1 :2003
EN 303-2:1998
EN 303-2/A1:2003

The validity of this certificate can be verified by means of a register available on the website www.kiwa.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)
Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it


www.kiwa.it
www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi



SGQ N° 007A SSI N° 006G
SGA N° 010D FSM N° 004I
PRD N° 069B



Organismo Notificato n. 0476



Number	KIP-15217/E	Replaces	KIP-15140/E
Issued	23-12-2016	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	150200348/2	Page	2 of 2
PIN	0476CQ0348		

EC TYPE EXAMINATION CERTIFICATE

ANNEX 1

Models:

	TAU 115 N OIL	TAU 150 N OIL	TAU 210 N OIL
Full load 80/60°C	97,6 %	97,6 %	97,7 %
Aver. load 80/60°C	97,7 %	97,7 %	97,7 %
Part load at 30°C	104,8 %	104,7 %	104,6 %
C.Heater?	no	no	no
B ₁ Boiler?	no	no	no
Type of boiler:	Condensing	Condensing	Condensing

	TAU 270 N OIL	TAU 350 N OIL	TAU 450 N OIL
Full load 80/60°C	97,9 %	98,2 %	98,2 %
Aver. load 80/60°C	97,9 %	98,2 %	98,2 %
Part load at 30°C	104,4 %	104,1 %	104,1 %
C.Heater?	no	no	no
B ₁ Boiler?	no	no	no
Type of boiler:	Condensing	Condensing	Condensing

Note:

C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)

B₁ Boiler = B₁ according CEN/TR 1749:2014

Type of boiler = "Condensing Boiler" or "Low Temperature Boiler" or Other Boiler"

Efficiency's values have been measured with OIL

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).