



Number	KIP-15890/E	Replaces	KIP-15069/E
Issued	03-08-2018	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	150500511/3	Page	1 of 2
PIN	0476CR0511		

EC TYPE EXAMINATION CERTIFICATE

Kiwa Cermet Italia, notified body for council Directive 92/42/EEC, hereby declares that according to article 4 of commission regulation (EU) No. 813/2013 the products

Low temperature heating boilers with atomizing oil burner

Trade mark: **RIELLO**

Models: GITRE' 4, GITRE' 5, GITRE' 6, GITRE' 5 B/100,
GITRE' 4 LN, GITRE' 5 LN, GITRE' 6 LN,
GITRE' 5 B/100 LN

Placed on the market by **Riello S.p.A.**
Via Ing. Pilade Riello, 7
37045 Legnago (VR) - Italy

Have achieved the following (see Annex 1) full and part load efficiencies.

The assessment test have been performed using the following standards as guidelines:

EN 303-1:2017, EN 303-2:2017, EN15035:2006

The validity of this certificate can be verified on request at the following e-mail address: info@kiwa.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and /or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadrano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it
www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi



Organismo Notificato n. 0476

SGQ N° 007A
SGA N° 010D
PRD N° 069B
FSM N° 004I
PRS N° 089C

Rev.8



Number KIP-15890/E Replaces KIP-15069/E
 Issued 03-08-2018 Scope Directive 92/42/EEC
 Regulation (EU) No. 813/2013
 Report 150500511/3 Page 2 of 2
 PIN 0476CR0511

EC TYPE EXAMINATION CERTIFICATE

ANNEX 1

Models:

	GITRE' 4	GITRE' 5	GITRE' 6	GITRE' 5 B/100
Full load 80/60°C	94,8 %	95,2 %	94,5 %	95,2 %
Part load at 37°C	96,9 %	96,1 %	95,6 %	96,1 %
C.Heater?	No	No	No	Yes
B ₁ Boiler?	No	No	No	No
Type of boiler:	Low Temperature	Low Temperature	Low Temperature	Low Temperature
Range Rated?	No	No	No	No

	GITRE' 4 LN	GITRE' 5 LN	GITRE' 6 LN	GITRE' 5 B/100 LN
Full load 80/60°C	95,3 %	96,1 %	96,2 %	96,1 %
Part load at 37°C	97,4 %	97,2 %	97,3 %	97,2 %
C.Heater?	No	No	No	Yes
B ₁ Boiler?	No	No	No	No
Type of boiler:	Low Temperature	Low Temperature	Low Temperature	Low Temperature
Range Rated?	No	No	No	No

Note:

C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)

B₁ Boiler = B₁ according CEN/TR 1749:2014

Type of boiler = "Condensig Boiler" or "Low Temperature Boiler" or Other Boiler"

Efficiency's values have been measured with OIL

(n.t.= not tested)

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensig boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

CERTIFICATE

Kiwa Cermet Italia S.p.A.
 Società con socio unico, soggetta all'attività di
 direzione e coordinamento di Kiwa Italia
 Holding Srl

Via Cadriano, 23
 40057 Granarolo dell'Emilia (BO)

Unità locale
 Via Treviso 32/34
 31020 San Vendemiano (TV)

Tel +39. 0438 411755
 Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it
www.kiwacermet.it