

Number	KIP-07660	Replaces	KIP-17075/G
Issue date	02-08-2024	Contract number	I 7230
Due date	01-08-2034	Scope	(EU) 2016/426 (9 March 2016)
Report number	2005430/3	Module	B (Type testing)
PIN	0476DM5430		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

**CONDEXA HPR 35,
CONDEXA HPR 45,
CONDEXA HPR 55,
CONDEXA HPR 70**

Manufacturer

RIELLO S.p.A.
Via Ing. Pilade Riello, 7
37045 Legnago (VR) - Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2021+A1:2023, EN15502-2-1:2022+A1:2023

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Industry Division Manager
Maurizio Lorenzon

Kiwa Cermet Italia S.p.A.
**Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl**

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

CERTIFICATE

Number KIP-07660 **Page** 1 of 1
Issue date 02-08-2024 **Scope** (EU) 2016/426 (9 March 2016)
Due date 01-08-2034 **Module** B (Type testing)
Report number 2005430/3
PIN 0476DM5430

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name: **RIELLO**

Types:

Model name	Appliance types	Heat Input (Hi)	
		CH Max – Min (kW)	DHW Max – Min (kW)
CONDEXA HPR 35	B _{23P} , B _{53P} , C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₆₃ , C ₈₃ , C ₉₃ , C _{13X} , C _{33X} , C _{43X} , C _{53X} , C _{63X} , C _{83X} , C _{93X}	34.9 – 5.2	34.9 – 5.2 ⁽¹⁾
CONDEXA HPR 45		45.0 – 5.2	45.0 – 5.2 ⁽¹⁾
CONDEXA HPR 55		55.0 – 8.2	55.0 – 8.2 ⁽¹⁾
CONDEXA HPR 70		70.0 – 8.2	70.0 – 8.2 ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for the domestic hot water production

Countries:

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:


Group	mbar	Group	mbar	Group	mbar
E	20	H	20;25	P	30;37;50
EY20	20	HY20	20;25	Esi	20/25

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Note: Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H₂) when the appliance is set for the reference gas G₂₀.

Remarks: --

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
 This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
 Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



Number	KIP-07661	Replaces	KIP-17075/E
Issue date	02-08-2024	Contract number	I 7230
Report number	2005430/3	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
PIN	0476DM5430	Module	B (Type testing)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the Central heating condensing boilers, type(s):

**CONDEXA HPR 35,
CONDEXA HPR 45,
CONDEXA HPR 55,
CONDEXA HPR 70**

Manufacturer

RIELLO S.p.A.
Via Ing. Pilade Riello, 7
37045 Legnago (VR) - Italy

meet the requirements regarding useful efficiencies according **to article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard: EN 15502-1:2021+A1:2023, EN15502-2-1:2022+A1:2023

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476

Industry Division Manager
Maurizio Lorenzon



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Number	KIP-07661	Page	1 of 4
Issue date	02-08-2024	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2005430/3	Module	B (Type testing)
PIN	0476DM5430		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:

RIELLO

Specifications:

Model(s):

CONDEXA HPR 35

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	34,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	11,3	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	87,7	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	97,4	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,4 %	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	108,2 %	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-07661	Page	2 of 4
Issue date	02-08-2024	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2005430/3	Module	B (Type testing)
PIN	0476DM5430		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:

RIELLO

Specifications:

Model(s):

CONDEXA HPR 45

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	43,9	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	14,6	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	87,8	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	97,2	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,5 %	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	107,9 %	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-07661	Page	3 of 4
Issue date	02-08-2024	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2005430/3	Module	B (Type testing)
PIN	0476DM5430		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:

RIELLO

Specifications:

Model(s):

CONDEXA HPR 55

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	53,6	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	17,8	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	87,8	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,9	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,46 %	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	107,61 %	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Number	KIP-07661	Page	4 of 4
Issue date	02-08-2024	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2005430/3	Module	B (Type testing)
PIN	0476DM5430		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:

RIELLO

Specifications:

Model(s):

CONDEXA HPR 70

Condensing boiler:	yes
Range rated:	no
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	68,2	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	22,6	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	87,8	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,8	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,48 %	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	107,51 %	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.