



Condexa Boiler Start-up Report

Energy For Life

Customer Representative (Print)	Signature:	Date (DD/MM/YY): / /
---------------------------------	------------	-------------------------

GENERAL INFORMATION					
TECHNICIAN:		DATE:			
JOB NAME:					
ADDRESS:					
CITY:		State/Prov.		Zip/Postal:	
MAKE:		MODEL:		SERIAL NO.	
CONTACT:		GAS TYPE:		DATE:	
SERVICE DETAILS					
TECHNICIAN REMARKS:			Wiring is connected correctly and tight:		
			Boiler safeties operate properly:		
			Gas valve operates properly:		
			Gas train has been checked for leaks:		
			Managing/Dependant:		
			Application:		
			System set point:		
WORK TO BE COMPLETED:			Primary sensor is mounted in primary loop:		
			Secondary sensor is mounted in secondary loop:		
			The distance between the service regulator and boiler is greater than 10':		
			Boiler static inlet pressure (in w.c):		
			Expansion tank installed:		
Tech Signature			Expansion tank pressure (PSI):		
Service Hours			Glycol %		

Boiler Cascade Setup

Boiler #	Parameter	Description	Units	Default Value	Final Value
1	73	Boiler address (set to 1)		Managing	
1	157	Emergency setpoint	Deg. F	158	
1	162	Hyst. down start boiler	Deg. F	9	
1	163	Hyst. up stop boiler	Deg. F	3.6	
1	164	Hyst. down quickstart	Deg. F	18	
1	165	Hyst. up quickstop	Deg. F	7.2	
1	166	Hyst. up stopall	Deg. F	14.4	

Module Cascade Setup

Parameter	Description	Units	Default Value	Final Value
72	Permanent emergency mode		Yes	
74	Emergency setpoint	Deg. F	158	
77	Hyst. down start module	Deg. F		
78	Hyst. up stop module	Deg. F	7.2	
84	Module rotation	Deg. F	5 days	
144	Hyst. down quickstart	Deg. F	18	
145	Hyst. up quickstop	Deg. F	7.2	
146	Hyst. up stopall	Deg. F	14.4	
149	First module to start		1	

Boiler Parmeters Setup

Parameter	Description	Units	Default Value	Final Value
1	CH Mode		0	
35	DHW Mode		0	
127	Programmable output 3 (set to 10 if OAD used)		0	

Overshoot/short cycling parameters:

If the boiler is overshooting setpoint / short cycling, We recommend the following parameter changes.

Overshoot/Short Cycling Parameter

Cascade Settings	Parameter	Description	Units	Recommended Value	Final Value
Module	79	Max. setpoint offset down	Deg. F	10	
Module	80	Max. setpoint offset up	Deg. F	10	
Module	87	PID I		250	
Module	150	PID slewrate up		5	
Module	151	PID slewrate down		5	
Boiler	169	Max setpoint offset down	Deg. F	15	
Boiler	170	Max setpoint offset up	Deg. F	15	
Boiler	177	PID I		500	
Boiler	178	PID slewrate up		5	
Boiler	179	PID slewrate down		5	

Low temperature system parameters (less than 100 deg f):

Please note for low temperature applications it is recommended to use the following parameters below.

Parameter 7 and 112 will need to be adjusted at each module.

Low Temperature Parameter Setup

Settings Level	Parameter	Description	Units	Recommended Value	Final Value
Param.	7	CH hyst. up	Deg. F	5	
Param.	112	CH hyst. down	Deg. F	5	
Module	79	Max. setpoint offset down	Deg. F	10	
Module	80	Max. setpoint offset up	Deg. F	10	
Module	87	PID I		250	
Module	150	PID slewrate up		5	
Module	151	Casc PID slewrate down		5	
Boiler	169	Max. setpoint offset down	Deg. F	15	
Boiler	170	Max. setpoint offset up	Deg. F	15	
Boiler	177	PID I		500	
Boiler	178	PID slewrate up		5	
Boiler	179	PID slewrate down		5	



Energy For Life

Condexa Boiler Start-up Report

Condexa

Burner	Gas		Fan Speed (RPM)	Chamber/Flue					Efficiency			Water			Flame Sig. (µA)
	Load Points	Gas Flow (SCFH)	Dynamic Inlet Gas (in w.c.)	Stack Draft (in w.c.)	O ₂ (%)	CO (ppm)	NO _x (ppm)	CO ₂ (%)	Ambient Temp (°F)	Flue Gas Temp (°F)	Eff. (%)	Water Flow (GPM)	Temp In (°F)	Temp Out (°F)	
Condexa	Ign.														
	Low														
	High														