



South Coast Air Quality Management District



21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

April 7, 2017

Mr. Blaine Serio
Riello Burners North America
2165 Meadowpine Blvd.
Mississauga, ON L5N6H6
Canada

Dear Mr. Serio:

As requested in the letter you submitted on April 5, 2017, the South Coast Air Quality Management District (SCAQMD) has certified by extension the attached list of water heater models and will be reflected in the updated product listing for all certified models.

The above certification by extension is approved based on the information you provided that these water heaters are identical in design with currently approved Riello Canada Inc. model that meet 14 ng/J or 20 ppm NO_x limit in Rule 1146.2.

Please note that the SCAQMD does not endorse or warrant any specific product or manufacturer. Modification of the products listed above will void this certification. If you have any questions or require further assistance, please contact me at (909) 396-2529 or by e-mail at stsai@aqmd.gov.

Sincerely,

A handwritten signature in cursive script, reading "Susan Tsai", is positioned above the typed name and title.

Susan Tsai
Senior Air Quality Engineer
Engineering & Permitting Division

Riello Canada Inc.**SCAQMD RULE 1146.2 CERTIFICATION LIST**
(Certified @ 14 ng/J NOx or 20 ppm NOx for Type 2)

Base Models Riello Canada Inc.	Extended Fontecal S.p.A Models	Maximum Heat Input Maximum (BTU/HR)
Steel Pro 150	AR 1000	1,000,000
Steel Pro 150	AR 1500	1,500,000
Steel Pro 150	AR 2000	2,000,000