

Number	88036/1	Replaces	--
Issued	29-05-2015	Scope	2009/142/EC 92/42/EEC
Report number	150201187		
PIN	0063CQ3187	Contract number	E6680

EC TYPE EXAMINATION CERTIFICATE

Kiwa hereby declares that the **Condensing Boilers**, types

Trade mark **RIELLO**

Models	Residence Condens 20 KIS i	Residence EXTERNA Condens 25 KIS i
	Residence Condens 20 IS i	Residence Condens 28 KIS i
	Residence IN Condens 20 IS i	Residence Condens 32 KIS i
	Residence EXTERNA Condens 20 IS i	Residence IN Condens 32 KIS i
	Residence Condens 25 KIS i	Residence EXTERNA Condens 32 KIS i
	Residence IN Condens 25 KIS i	Residence Condens 32 IS i

supplied by **RIELLO S.p.A.**

Legnago (VR), Italy

meet the essential requirements as described in the
Directive 2009/142/EC relating to appliances burning gaseous fuels and the
Directive 92/42/EEC on efficiency requirements.


Appliance types : B_{23P}, B_{53P}, C₁₃, C₂₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃
C_{13X}, C_{33X}, C_{43X}, C_{53X}, C_{63X}, C_{83X}, C_{93X}

Appliance categories : I_{2H}, I_{2E}, I_{3P} * I_{2HM} (see notes)

Countries:

Albania	France	Lithuania	Slovakia
Austria	Germany	Luxembourg	Slovenia
Bulgaria	Greece	Netherlands, the	Spain
Croatia	Hungary	Norway	Sweden
Czech Republic	Ireland	Poland	Switzerland
Denmark	Iceland	Portugal	Turkey
Estonia	Italy	Romania	United Kingdom
Finland	Latvia	Republic of Macedonia	


* gas category valid only for appliances mod. Residence Condens 25 KIS i, Residence IN Condens 25 KIS i, Residence EXTERNA Condens 25 KIS i



Bouke Meekma
Kiwa

kiwa
Approved

EC Directive



2009/142/EC
92/42/EEC

G A S T E C

CE
0063

Number 88025/1 Replaces --
Issued 29-05-2015 Scope 92/42/EEC
Report number 150201187
PIN 0063CQ3187

Energy Performance Labels Declaration

Kiwa hereby declares that the central heating condensing boiler, types

Trade mark:	RIELLO		
Types	Efficiency values		
	Full load 80/60°C (%)	Part load 30°C (%)	Star label:
Residence Condens 20 KIS i	97,9	109,6	★★★★★
Residence Condens 20 IS i	97,9	109,6	★★★★★
Residence IN Condens 20 IS i	97,9	109,6	★★★★★
Residence EXTERNA Condens 20 IS i	97,9	109,6	★★★★★
Residence Condens 25 KIS i	97,9	109,6	★★★★★
Residence IN Condens 25 KIS i	97,9	109,6	★★★★★
Residence EXTERNA Condens 25 KIS i	97,9	109,6	★★★★★
Residence Condens 28 KIS i	98,1	109,5	★★★★★
Residence Condens 32 KIS i	97,8	109,5	★★★★★
Residence IN Condens 32 KIS i	97,8	109,5	★★★★★
Residence EXTERNA Condens 32 KIS i	97,8	109,5	★★★★★
Residence Condens 32 IS i	97,8	109,5	★★★★★

supplied by **Riello S.p.A.**

Legnago (VR), Italy

have been awarded the star labels based on the
Directive on efficiency requirements (92/42/EEC) Annex II of 21 May 1992
amended by Rectification of 22 June 1992 (O.J. L 167), by
Directive 93/68/EEC of 22 July 1993 and by Directive 04/8/EC of
11 February 2004.

Kiwa Nederland B.V.



Ing. A.A. Slomp
Certification Manager.


Kiwa Nederland B.V.
Wilmsdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands

www.1kiwa.com

GASTEC

kiwa
Approved

EC Directive



92/42/EEC

GASTEC