



DECLARATION

Issued	21-04-2018	Scope	---
Report	150700325/4	Page	1 of 1
PIN	0476CQ0325		

Herewith Kiwa Cermet Italia S.p.a. declares that the central heating condensing boilers

Test report no. 150700325/4

Trade mark: RIELLO

Models: Family Externa Condens 3.0 KIS E
Family IN Condens 3.0 KIS E
Family IN Condens 3.0 IS E
Residence IN Hybrid 25 KIS
Residence IN Hybrid 25 IS
Residence IN Hybrid 32 KIS
Residence Hybrid 25 KIS
Residence Hybrid 32 KIS

are fitted for outdoor use in partially protected place according to EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016 with minimum ambient tempertaure of -15°C.

Models: Residence IN Condens 20 IS i
Residence EXTERNA Condens 20 IS i
Residence IN Condens 25 KIS i
Residence EXTERNA Condens 25 KIS I
Residence IN Condens 32 KIS i
Residence EXTERNA Condens 32 KIS i

are fitted for outdoor use in partially protected place according to EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016 with minimum ambient tempertaure of -10°C.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it
www.kiwacermet.it

Industry Division Manager
Maurizio Lorenzon

GASTEC